



ORDER

№ A 129

Sofia, 01.04.2024

On the grounds of art. 10, para. 1, item 4, art. 28, para. 1 of the Law on the National Accreditation of Conformity Assessment Bodies and the respective item 4.3.7 of the Accreditation Procedure BAS QR 2 in connection with an open procedure with reg. № 320/16 OKC/ПА/18.10.2023, on-site assessment report № 320/16 OKC/ПА/4/24.01.2024, section G-2 inc. ref. № 320/16 OKC/ПА/7/В/28.02.2024 and statement of the Accreditation Commission № 320/16 OKC/ПА/8/В/ 26.03.2024, I hereby

RE-ACCREDIT

**Inspection Body "Nadezhda" of TYPE C
at " Nadya 2005" Ltd.,Sofia**

Management address: 1612 Sofia, Lagera housing estate, bl. 80 B, ap. 36

Office address: 1000 Sofia, Oborishte Neighbourhood, 16 Stara Planina str.

To perform inspection according to the following scope:

Type of scope: flexible*					
№	Field of inspection	Type of inspection	Parameter of Inspection/ Characteristic	Test and Measurement Methods Used During Inspection, Inspection Procedure	Regulations, Standards, Specifications, Schemes
1	2	3	4	5	6
1.	PHYSICAL FACTORS IN WORKING AND HOUSEHOLD ENVIRONMENT:				
1.1	Artificial illumination in working and household environment	Of new and/or in use/ operation sites/ facilities	Illumination	Methodical instructions for measurement and evaluation of artificial lighting in buildings 40-85, Standardization Publishing House 1985.; ПК 1	Ordinance No. 49, (SG, No. 7/1976); Ordinance No. 9, (SG, No. 46/1994); Ordinance No. 24, (SG, No. 95/2003); Ordinance No. 2, (SG, No.15/2007); БДС EN 12464-1 TS
1.2	Working and household environment microclimate	Of new and/or in use/ operation sites/ facilities	- Air temperature; - Relative air humidity; - Air velocity	БДС 16686; Ordinance No. РД-07-3 (SG, No. 63/2014) ПК 2	Ordinance No. 9, (SG, No. 46/1994); Ordinance No. 2, (SG, No. 15/2007); Ordinance No. 24, (SG, No. 95/2003);

					Ordinance No. РД-07-3 (SG, No. 63/2014); БДC 14776; TS
1.3	NOISE				
1.3.1	Noise in working environment	Of new and/or in use/ operation sites/ facilities	-Daily noise exposure level, -Average weekly noise exposure level; -Peak sound pressure level	БДC EN ISO 9612 (БДC ISO 1999); ПК 3	Ordinance No. 6, (SG, No. 70/2005.) TS
1.3.2	Noise in territories and development zones in urban areas and outside them	Of new and/or in use/ operation sites/ facilities	-Equivalent noise level	БДC 15471; ПК 3	Ordinance No. 6, SG, No. 58/2006– (Annex No. 2, tab. 2); TS
1.3.3	Noise in residential and public buildings premises	Of new and/or in use/ operation sites/ facilities	-Noise level; -Equivalent noise level	БДC 15471; ПК 3	Ordinance No. 2 (SG, No. 15/2007); Ordinance No. 6 (SG, No. 58/2006 (Annex No. 2, tab. 1); Ordinance No. 9 (SG, No. 46/1994); Ordinance No. 24 (SG, No. 95/2003); TS
2.	ELECTRIC ASSEMBLIES AND FACILITIES UP TO 1000 V:				
2.1	Electric assemblies and facilities up to 1000 V	Of new and/or in use/ operation sites/ facilities	-Insulation resistance	БДC 1986 item 3.3, (a), (6), (d) and (e); ПК 5	Ordinance No. 3, SG, No. 90.91/2004; Ordinance No. 16-116 SG, No. 26/2008; Ordinance No. 9, SG, No. 72/2004; TS
2.2	Electric assemblies and facilities up to 1000 V	Of new and/or in use/ operation sites/ facilities	-Impedance of the "phase – protective conductor circuit"	ПК 6	Ordinance No. 3, SG, No. 90.91/2004.; Ordinance No. 16-116 SG, No. 26/2008; TS
2.3	Electric assemblies and facilities up to 1000 V	Of new and/or in use/ operation sites/ facilities	Safety fuse breakers: -Trigger current -Protective earthing resistor; -Contact voltage	ПК 7	Ordinance No. 3, SG, No. 90.91/2004.; Ordinance No. 16-116 SG, No. 26/2008; TS

2.4	Electric assemblies and facilities up to 1000 V	Of new and/or in use/ operation sites/ facilities	-Safety grounding systems resistance	ПК 8	Ordinance No. 3, SG, No. 90.91/2004.; Ordinance No. 16-116 SG, No. 26/2008; TS
2.5	Electric assemblies and facilities up to 1000 V	Of new and/or in use/ operation sites/ facilities	-Resistance of lightning protection earthing systems	ПК 9	Ordinance No. 4, (SG, No. 6/2011); Ordinance No. 3, SG, No. 90,91/2004.; Ordinance No. 16-116 SG, No. 26/2008; TS
3.	VENTILATION INSTALLATIONS:				
3.1	Ventilation installations	Of new and/or in use/ operation sites/ facilities	-Airflow velocity; -Airflow rate	БДС 12.3.018; ПК 10	Ordinance No. 15, SG, No. 78/2005; TS

* The introduction of a new version of standards / documents or standards/documents that replace them is allowed. An up-to-date list of standards/documents with their dated versions is provided by the CAB

Ordinance No. 2 on the health requirements to the computer and internet halls for public use (SG No. 15/2007).

Ordinance No. 3 on the structure of electrical installations and power lines (SG, No. 90/2004, SG, No. 91/2004).

Ordinance No. 4 on lightning protection of buildings, exterior facilities and open spaces (SG, No. 6/2011).

Ordinance No. 6 on the minimum requirements for ensuring the health and safety of workers in case of risks related to noise exposure (SG No. 70/2005)

Ordinance No. 6 on the noise indicators in the environment taking into account the degree of discomfort during different parts of the day, limit values of noise indicators in the environment, in the premises of residential and public buildings, in areas and territories intended for residential construction, recreational areas and territories and mixed-use areas, methods for assessing the values of noise indicators and the harmful effects of noise on the health of the population (SG, No. 58 /2006)

Ordinance No. 9 on the health and hygiene requirements for the use of personal computers in the education and extracurricular activities of students (SG No. 46/1994)

Ordinance No. 9 on the technical operation of power plants and networks (SG, issue 72/2004)

Ordinance No. 15 on technical rules and regulations for the design, construction and operation of the sites and facilities for the production, transmission and distribution of thermal energy (SG, No. 68/2005)

Ordinance No. 24 on the sanitary and hygienic requirements to the discotheques (SG No. 95/2003)

Ordinance No. 49 on artificial lighting of buildings (SG No. 7/1976)

Ordinance ПД-07-3 on the minimum requirements for the microclimate of workplaces (SG, No. 63/2014)

Ordinance No. 16-116 on the technical operation of the energy equipment (SG, No. 26/2008)

TS – Technical specification


I ORDER

The issuance of Certificate of accreditation reg. № 16 OKC from 01.04.2024 valid until 01.04.2028 with this order enclosed as an integral part thereof.

The receipt of the Certificate of accreditation together with its enclosure should be received by the Manager of "Nadya 2005" Ltd., Sofia, the Head of the Control Body of type C "Nadezhda" at "Nadya 2005" Ltd., Sofia or other authorized person in the office of EA BAS.

Upon receipt of the issued certificate and the enclosure, the accredited person shall return to EA BAS the originals of the Certificate of accreditation reg. № 16 OKC of 26.02.2021, valid until 01.04.2024 and the enclosure Order for Accreditation № A 111/26.02.2021 of EA BAS.

This Order shall be notified to "Nadya 2005" Ltd., town Sofia within 3 (three) days as from its issuance.


Dipl. Eng. IRENA BORISLAVOVA
Executive Director
EA BAS

