

BAS reg. Nº 55 OKC

From: 19.06.2023 Valid until: 19.06.2027



"TPP - Bobov Dol" Ltd., village of Golemo Selo, Kyustendil Region Inspection Body "Defectoscopy" of TYPE C

Management address: 2635, village of Golemo Selo, Kyustendil Region

Office address: 2635, village of Golemo Selo, Kyustendil Region, Bobov dol Municipality, administration building, floor 8, offices 1 and 2

UIC: 109513731

## Scope of Accreditation:

To perform inspection of:

Metal products (seamless pipes, rolled products, forgings, castings), lifting equipment, gas equipment and installations, boilers, pressure vessels, pipelines and tanks - base metal and welded joints - non-destructive inspection:

- Type, size and location of non-integrity/imperfections by radiographic method of inspection;
- Type, size and location of imperfections/imperfections by ultrasonic inspection method;
- Wall thickness by ultrasonic inspection method;
- -Type and size of surface and subsurface non-integrity/imperfections by magnetic-powder inspection method;
- Type and size of surface non-integrity/imperfections by capillary inspection method;
- Type and size of surface non-integrity /imperfections by visual inspection method;
- Brinell, Rockwell and Vickers hardness test measure by the Lieb's method;
- Measurement of linear dimensions /ovality/.

## ACCREDITED ACCORDING TO БДС EN ISO/IEC 17020:2012

Order № A 243/19.06.2023 is an integral part of the Certificate of accreditation.

5 pages totally.

Date of initial accreditation: 04.05.2011
Date of re-accreditation: 19.06.2023

Eng. Irena Borislavova

Executive Director

LY DAS

BG 2 0 2 4 1 4 6

1797 Sofia, "Dr. GM Dimitrov "№ 52 A, 7th floor Tel.: ++359 2 9766401, Fax: ++359 2 9766415 e-mail: office@nab-bas.bg

http://www.nab-bas.bg