REPUBLIC OF BULGARIA
Executive Agency
Bulgarian Accreditation Service
Signatory to the EA Multilateral Agreement in this field

ORDER

No. A 197

Sofia, 29.05.2024

Pursuant of Art. 10, para. 1, item 4, Art. 28, para. 1 of the Law on National Accreditation of Conformity Assessment bodies and item 4.3.7 of the BAS QR 2 Accreditation Procedure, in connection with an open procedure with reg. № 338/84 ОКС/ПА/ 17.11.2023, evaluation report № 338/84 ОКС/ПА/3/В/29.02.2024, and annex G-2 with reg. № 338/84/ОКС/6/В/10.04.2024 and opinion of the Accreditation Commission № 338/84 ОКС/ПА/7/В/21.05.2024, I hereby

RE-ACCREDIT

INSPECTION BODY "CABLE CONTROL" TYPE C at CABLE GROUP Ltd., city of Pazardzhik

Management and office address: 4400 city of Pazardzhik,35 "Dimcho Debelyanov" str.

To perform inspection according to following scope of:

Scope type: *flexible* *

№	Field of Inspection	Type of Inspection	Parameter of Inspection / Characteristic	Test and Measurement Methods Used During Inspection	Regulations, Standards, Specifications, Schemes
1	2	3	4	5	6
1	Microclimate in working and living environment	New and commissioned sites and facilities	Air temperature; Relative air humidity; Air flow rate.	БДС 16686 Ordinance No РД-07- 3 SG, No 63/2014 ПК-А-01-01	Ordinance No 2, SG No 15/2007; Ordinance No 3, SG No 15/2007; Ordinance No 9, SG, No 46/1994; Ordinance No 24 SG, No 95/2003; Ordinance No РД-07-3 SG, No 63/2014; БДС 14776; TS
2	Artificial lighting of working and living environment	New and commissioned sites and facilities	Illumination	Methodological guidelines for measurement and evaluation of artificial lighting in buildings, 40-85, Publishing House "Standartizatsiya" 1985; ПК-А-01-02	Ordinance No 2, SG No 15/2007; Ordinance No 3, SG No 15/2007; Ordinance No 9, SG, No 46/1994; Ordinance No 24 SG, No 95/2003; Ordinance No 49 SG, No 7/1976; БДС EN 12464-1; TS

1797 Sofia, G.M. Dimitrov, MD Blvd. No. 52 A, Floor 7
Tel.: 02 976 6401, fax: 02 976 6415
e-mail: office@nab-bas.bg

3	Noise in residential and public buildings	New and commissioned sites and facilities	noise level equivalent noise level	БДС 15471; ПК-А-01-03	Ordinance No 6 SG, No 58/2006 – annex 2, table 1 – p. 3, p. 4, p. 5, p. 6, p. 7; Ordinance No 9 SG, No 46/1994; Ordinance No 2 SG, No 15/2007; Ordinance No 24 SG, No 95/2003; Ordinance No 7 SG, No 88/1999; TS
4	Electrical appliances, devices and equipment up to 1000 V	New and commissioned sites and facilities	Impedance of the circuit "phase - protective conductor"	ПК-А-02-01	Ordinance No 16-116, SG, No 26/2008; Ordinance No 3, SG, No 90 and 91/2004; TS
5			Insulation resistance	БДС 1986 – p. 3.3 – а, б, д, and е; ПК-А-02-05	Ordinance No 3, SG, No 90 and 91/2004; Ordinance No 16-116, SG, No 26/2008; TS
6			Resistance of protective earthing systems	ПК-А-02-02	Ordinance No 16-116, SG, No 26/2008; Ordinance No 3, SG, No 90 and 91/2004; TS
7			Resistance of lightning protection earthing systems	ПК-А-02-03	Ordinance No 4, SG, No 6/2011; TS
8			Circuit breakers: - actuation current - resistance of protective earthing switch	ПК-А-02-04	Ordinance No 16-116, SG, No 26/2008; Ordinance No 3, SG, No 90 and 91/2004; TS
9	Climatic installations	New and commissioned sites and facilities	Air temperature; Relative air humidity	БДС 16686; Ordinance No РД-07-03 SG No 63/2014, ПК-А-03-01	БДС 14776; Ordinance No 15, SG, No 68/2005 Ordinance No РД-07-03 SG No 63/2014; TS
10	Ventilation installations	New and commissioned sites and facilities	Air rate Airflow rate	БДС 12.3.018; ПК-А-04-01	Ordinance No 15, SG, No 68/2005; Ordinance No 24, SG, No 95/2003; TS

** Introduction of new versions of standards/documents or superseding standards/documents is allowed. An updated list of standards/documents with their dated versions is provided by the CAB.*

Ordinance No 3 on the arrangement of electrical appliances and power lines, (SG, No 90 and No 91/2004)
Ordinance No 16-116 on the technical exploitation of the energy equipment, (SG, No 26/2008)
Ordinance No 4 on lightning protection of buildings, exterior facilities and open spaces (SG, No 45/2006)
Ordinance No 2 on the health requirements for computer and Internet halls for public use (SG No 15/2007)

Ordinance No 3 on the health requirements for kindergartens (SG No 15/2007)
Ordinance No 9 on the health hygiene requirements for the use of personal computers in the education and extra-curricular activities of students (SG, No 46/1994)
Ordinance No 24 on sanitary and hygiene requirements for disc dance clubs (SG, No 95/2003)
Ordinance No РД-07-3 (SG, No 63/2014) on the minimum requirements for the microclimate of workplaces
Ordinance No 7 on the minimum requirements for healthy and safe working conditions at workplaces and when using the workplace equipment (SG No 88/1999)
Ordinance No 6 for environmental noise indicators taking into account the degree of discomfort during the different parts of the day, the limit values of the indicators of noise in the environment, in the premises of residential and public buildings, in zones and territories intended for residential construction, recreational zones and territories and mixed-use zones, the methods for evaluating the values of the noise indicators and the harmful effects of noise on the health of the population (SG, No 58/2006)
Ordinance No 15 on technical rules and regulations for the design, construction and operation of the sites and facilities for the production, transmission and distribution of thermal energy (SG, No 68/2005)
TS – Technical specification.

I ORDER

To issue the Certificate of Accreditation reg. № 84 ОКС of 29.05.2024, valid until 29.05.2028, and this order enclosed as an integral part thereof.
The certificate of accreditation with the enclosure should be obtained from manager/representative of the CABLE GROUP Ltd., city of Pazardzhik, the Head of the CAB or other authorized person in the building of EA BAS.
Upon receipt of the issued certificate of accreditation and application, the accredited person is obliged to return to BAS EA the originals of the certificate of accreditation Reg. No. 84 ОКС/ 10.12.2021 and application-Order No. А 774 of 10.12.2021.
This Order shall be notified to legal entity / sole trader within 3 (three) days from its issuance.

Eng. Irena Borislavova
Executive Director of EA BAS