



ORDER

No. A 359
Sofia, 30.09.2024

Pursuant to Article 10 Para 1 (4) and Article 28 Para 1 of the Law on National Accreditation of Conformity Assessment Bodies Act and item 6 of the Accreditation Procedure BAS QR 2 in connection with open procedure Registration No. 57/110 OKC/ПА/15.02.2024, Assessment Report Reg. No. 57/110 OKC/ПА/6/В/30.05.2024 and statement of the Accreditation Commission № 57/110 OKC/ПА/8/В/04.09.2024, I hereby

RE-ACCREDIT

INSPECTION BODY OF TYPE C
at "LOZETECH" OOD, Sofia
Address of management and office:

72 Tsvetna Gradina Str., Lozenets Residential Area, 1421 Sofia

To perform inspection of:

Scope Type: flexible*					
No.	Area of control	Type of control	Controlled parameter / feature	Testing methods / measurement, used in the control	Legislative acts, standards, specifications, schemes
1	2	3	4	5	6
1	Noise in working environment	Of new sites / facilities and/or sites / facilities in operation	Peak sound pressure level, Daily noise exposure level, Average weekly noise exposure level	БДC EN ISO 9612 (БДC ISO 1999)	Ordinance No. 6, SG No. 70/2005; TC
2	Noise on the premises of residential and public buildings	Of new sites / facilities and/or sites / facilities in operation	Equivalent noise level, Noise level	БДC 15471 WP 7.1-02	Ordinance No. 24, SG No. 95/2003; Ordinance No. 2, SG No. 15/2007; Ordinance No. 26 SG No. 103/2008; Ordinance No. 6, SG No. 58/2006 (Appendix No. 2, Table 1); Ordinance No. 9, SG No. 46/1994; Ordinance No. 7, SG No. 88/1999; TC
3	Environmental noise - various territories and spatial development zones in and outside urban areas;	Of new sites / facilities and/or sites / facilities in operation	Equivalent noise level	БДC 15471 WP 7.1-02	Ordinance No. 6, SG No. 58/2006 (Appendix No. 2, Table 2); TC
					Ordinance No. 2, SG No. 15/2007;

4	Artificial light in working and living environment	Of new sites / facilities and/or sites / facilities in operation	Illumination	Methodological instructions for measurement and assessment of artificial light in buildings 40-85 / 1985 WP 7.1-03	Ordinance No. 49, SG No. 7/1976; Ordinance No. 26, SG No. 103/2008; БДC EN 12464-1, Ordinance No. 3, SG No. 15/2007; Ordinance No. 9, SG No. 46/1994; Ordinance No. 24, SG No. 95/2003; TC
5	Microclimate in working and living environment	Of new sites / facilities and/or sites / facilities in operation	Air temperature, Relative air humidity, Air velocity	БДC 16686 Ordinance No. RD-07-3 SG No. 63/2014 WP 7.1-04	Ordinance No. 24, SG No. 95/2003; Ordinance No. 2, SG No. 15/2007; Ordinance No. 3, SG No. 15/2007; Ordinance No. 9, SG No. 46/1994; Ordinance No. 26, SG No. 103/2008; БДC 14776; Ordinance No. RD-07-3 SG No. 63/2014; TC
6	Electrical installations and equipment below and above 1000 V	Of new sites / facilities and/or sites / facilities in operation	Earthing resistance of lightning protection systems,	WP 7.1-09	Ordinance No. 16-116, SG No. 26/2008; Ordinance No. 4, SG No. 6/2011; TC
7			Earthing resistance of ground protection systems,	WP 7.1-08	Ordinance No. 3, SG Nos. 90 & 91/2004; Ordinance No. 16-116, SG No. 26/2008; TC
8	Electrical installations and equipment below 1000 V	Of new sites / facilities and/or sites / facilities in operation	<i>Impedance of the "phase-protective conductor" contour</i>	WP 7.1-06	Ordinance No. 3, SG No. 90 & 91/2004; Ordinance No. 16-116, SG No. 26/2008; TC
9			Insulation resistance	БДC 1986 – item 3.3 a), b), e) & f) WP 7.1-07	Ordinance No. 3, SG No. 90 & 91/2004; Ordinance No. 16-116, SG No. 26/2008; TC
10			Protective circuit breakers: -Tripping time -Trigger current -Contact voltage	WP 7.1-10	Ordinance No. 3, SG No. 90 & 91/2004; Ordinance No. 16-116, SG No. 26/2008; TC

* It is allowed to introduce a new version of standards/documents or standards/documents replacing them. The updated list of standards/documents with their dated versions shall be provided by the Conformity Assessment Body.

Ordinance No. 2 concerning the health requirements for the public access computer and internet centers (SG No. 15/2007);
Ordinance No. 3 concerning the health requirements for kindergartens (SG No. 15/2007);
Ordinance No. 24 concerning the sanitary and hygienic requirements for discotheques (SG No. 95/2003);
Ordinance No. 9 concerning the hygienic requirements for using personal computers in teaching pupils (SG No. 46/1994);
Ordinance RD 07-3 concerning the minimum requirements for the microclimate at the workplaces dated 18.07.2014, published in SG No. 63/01.08.2014);

Ordinance No. 49 concerning artificial light of the buildings (SG No. 7/1976);
Ordinance No. 6 concerning the minimum requirements for ensuring the health and safety of the people working in risky conditions related to exposition to noise (SG No. 70/2005);
Ordinance No. 6 concerning the environmental noise indicators taking into account the degree of discomfort during different parts of the day, the limit values of the environmental noise indicators, in the premises of residential and public buildings, in areas and territories intended for residential construction, recreational areas and territories, and mixed-use areas, the methods for assessing the values of the noise indicators and the harmful effects of noise on the health of the population (SG No. 58/ 2006), Amended Title, SG 100/2021);
Ordinance No. 7 concerning the minimum requirements for healthy and safe conditions at work when using the working equipment (SG No. 88/1999);
Ordinance No. 26 concerning the structure and activity of nurseries and children's catering services and the health requirements for them (SG No. 103/2008);
Ordinance No. 3, SG Nos. 90 and 91/2004 concerning the structure of the electricity installations and electricity lines;
Ordinance No. 16-116, SG No. 26/2008 concerning the technical operation of power equipment;
Ordinance No. 4, SG No. 6/2011 concerning the lightning protection of buildings, outdoor facilities and open spaces.

ORDER

To issue the Certificate of Accreditation Registration No. 110 OKC dated 30.09.2024, valid until 30.09.2028 and this Order enclosed as an integral part thereof.

The Certificate of Accreditation with the enclosure should be obtained from Manager of "LOZETECH" OOD, Sofia, a representative of "LOZETECH" OOD, Sofia, the head of Inspection Body Type "C" or another authorized person in the building of EA BAS.

Upon receipt of the certificate issued and enclosure, the accredited CAB is obliged to return to EA BAS the originals of Certificate of Accreditation reg. № 110 OKC dated 30.09.2020 and Appendix-Order No. A 588/30.09.2020 issued by EA BAS.

This Order shall be notified to "LOZETECH" OOD, Sofia not later than 3 (three) days from its issuance.

Eng. Irena Borislavova
Executive Director of EA BAS

