REPUBLIC OF BULGARIA
Executive agency
Bulgarian accreditation service

Signatory to the EA Multilateral Agreement in this field

ORDER

№ A 458

Sofia, 18.07.2022

Pursuant to Art. 10, para. 1, item 2a of the Law on the National Accreditation of Conformity Assessment Bodies and according to item t.4.3.8 f) of the BAS QR 2 Accreditation Procedure, report № 383/282 ОКС/13/В/28.03.2022, and Annex to the Report (Section G-2) reg. № 383/282 ОКС/15/В/18.07.2022, and EA BAS order reg № А 457/18.07.2022

I AMEND

EA BAS order reg. № А 255/29.04.2021

INSPECTION BODY OF TYPE C
AT REIJ LTD, PIRDOP

Management Address: 1510, Sofia, Hadzhi Dimitar Residential Area,

block 25, entrance D, flat 58
Address of the CAB: 2070, Pirdop, 2 Georgi Benkovski Street

To perform inspection:

Type of scope: *Flexible**

№	Field of Inspection	Type of Inspection	Parameter of Inspection / Characteristic	Test and Measurement Methods Used During Inspection	Regulations, Standards, Specifications, Schemes
1	2	3	4	5	5
1.	Electrical installations and equipment up to and above 1000 V.	Installed on new and/or used sites/facilities	Insulation resistance	СР 7.1-6	Ordinance №16-116, SG №26/2008; Ordinance №3 SG №90/2004, №91/2004; TS
			Protective grounding installation resistance	СР 7.1-1	Ordinance №16-116, SG №26/2008; Ordinance № 3 SG № 90/2004, № 91/2004; TS
			Lightning protection and grounding installation resistance	СР 7.1-2	Ordinance № 4 SG № 6/2011; Ordinance № 16-116, SG №26/2008; TS
2.	Cable lines with voltage up to 20 kV.	Installed on new and/or used sites/facilities	Electric resistance of insulation through increased constant	НИЕМС СР 7.1-5	Ordinance №16-116, SG №26/2008; Ordinance №3 SG №90/2004, №91/2004; НИЕМС – 1995;

Type of scope: *Flexible**					
№	**Field of Inspection**	**Type of Inspection**	**Parameter of Inspection / Characteristic**	**Test and Measurement Methods Used During Inspection**	**Regulations, Standards, Specifications, Schemes**
1	2	3	4	5	5
			voltage		TS
3.	Electrical installations and equipment up to and above 1000 V.	Installed on new and/or used sites/facilities	Impedance of the "phase-protective conductor" contour	CP 7.1-3	Ordinance №16-116, SG №26/2008; Ordinance №3 SG №90/2004, №91/2004; TS
			Protective circuit breakers: Contact voltage, trigger current, shut-off time	CP 7.1-4	Ordinance №16-116, SG №26/2008; Ordinance №3 SG №90/2004, №91/2004; TS

***Flexible scope:** Introduction of new versions of standards/documents or standards/documents that replace them is allowed. An up-to-date list of standards/documents with their dated versions is provided by the CAB*

Ordinance № 3 on the structure of electrical systems and power transmission lines (SG № 90/2004 and № 91/2004, amended and supplemented in the SG, № 92/2013);
Ordinance № 16-116 on the technical use of power equipment (SG № 26/2008; amended and supplemented in the SG № 4/2015);
Ordinance № 4 on the lightning protection of buildings, outdoor facilities and open spaces (SG № 6/2011);
НИЕМС-1985 Methodology instruction for measuring and evaluation of artificial illumination in buildings 40-85, Standardisation Publishing House 1985;
TS - technical specification.

I ORDER

To issue the certificate of accreditation reg. № 282 ОКС/18.07 2022, validity until 29.04.2025, and this order as an integral part of it.

The certificate of accreditation with the enclosure to be received by the Manager of the legal entity, the head of the CAB, or other authorized person in the office of EA BAS.

Upon receipt of the certificate and the enclosure, the accredited person is obliged to return to EA BAS the originals of accreditation certificate Reg. No 282 ОКС/29.04.2021 and its enclosure.

This order shall be notified to REIL LTD, Sofia within 3 (three) days from its issuance.

Eng. IRENA BORISLAVOVA

Executive Director of EA BAS