



Signatory to the EA Multilateral Agreement in this field

ORDER

№ A 503

Sofia, 27.12.2024

Pursuant to Art. 10, paragraph 1, items 4, Article 28, paragraph 1 of the Law on National Accreditation of Conformity Assessment Bodies, and items 6 of Accreditation Procedure BAS QR 2, in connection with open procedure with Reg. № 364/98 OKC/ПА/13.05.2024 Reg. № 364/98 OKC/6/B/02.08.2024, Section (Annex) G-2 № 364/98 OKC/ПА/8/B/ 22.11.2024, and statement of the Accreditation Committee № 364/98 OKC/ПА/9/B/17.12.2024, I hereby

RE-ACCREDIT

**STM-VITA LTD, RAZGRAD
TYPE C INSPECTION BODY**

Management and office address: 7200 Razgrad, RC Osvobozhdenie, bl. 68

To perform control, according to the following range:

№	Field of inspection	Type of inspection	Parameter / feature inspected	Test / measurement methods used in inspection; inspection procedure	Regulations, standards, specifications, control schemes
1	2	3	4	5	6
Scope type: flexible*					
1.	Noise in the working environment	At new and/or operational sites / facilities	Noise level, Equivalent noise level Daily noise exposure level, Average weekly noise exposure level – Peak sound pressure	БДС ISO 1999 (БДС EN ISO 9612) РП ОК 10-2	Ordinance 6/2005, (SG 70/2005) TS
2.	Noise in the surrounding environment, in different territories and development zones in urbanized territories and outside of them	At new and/or operational sites / facilities	Equivalent noise level	БДС 15471 РП ОК 10-2	Ordinance 6/2006, (SG 58/06), Appendix 2 to Table 2 TS

3.	Noise in premises within residential and public buildings	At new and/or operational sites / facilities	Noise level, Equivalent noise level	БДC 15471 ПП ОК 10-2	Ordinance № 6 (SG 16/1977) Ordinance № 6 (SG 58/2006) - Appendix 2 to Table 1 Ordinance № 9 (SG 46/1994) Ordinance № 24 (SG 95/2003) Ordinance № 2 (SG 15/2007) Ordinance № 26 (SG 103/2008) TS
4.	Artificial lighting in work and home environments	At new and/or operational sites / facilities	Luminosity	Methodological guidance on measuring artificial lighting - 1985, Standartizacia publisher ПП ОК 10-6	Ordinance № 49 (SG 7/1976) Ordinance № 24 (SG 95/2003) Ordinance № 9 (SG 46/1994) Ordinance № 2 (SG 15/2007) Ordinance № 3 (SG 15/2007) Ordinance № 26, (SG 103/2008) Ordinance ПД-02-20- 3/ (SG 5/ 2016) БДC EN 12 464-1 TS
5.	Microclimate in work and living environment	At new and/or operational sites / facilities	Air temperature Relative humidity of air Airflow velocity	БДC 16 686 Ordinance № ПД-07- 3, SG 63/2014 ПП ОК 10-1	Ordinance ПД-02-20- 3/ (SG 5/ 2016) Ordinance № 3 (SG 15/2007) Ordinance № 9 (SG 46/1994) Ordinance № 2 (SG 15/2007) Ordinance № 24 (SG 95/2003) Ordinance № 26, (SG 103/2008) Ordinance № ПД-07-3 (SG 63/2014) БДC 14776 TS
6	Ventilation systems	At new and/or operational sites / facilities	Airflow velocity Air flow	БДC 12.3.018 ПП ОК 10-8	Ordinance № 24 (SG 95/2003) Ordinance № 15, (SG 68/2005) TS

7	Electrical installations and equipment up to 1000 V	At new and/or operational sites / facilities	Resistance of protective earthing systems	ПП ОК 10-3	Ordinance № 3 (SG 90 & 91/2004) Ordinance № 16-116 (SG 26/2008) TS
		At new and/or operational sites / facilities	Resistance of lightning protection earthing systems	ПП ОК 10-4	Ordinance № 4 (SG 6/2011) TS
		At new and/or operational sites / facilities	Impedance of the phase-protective wire circuit	ПП ОК 10-5	Ordinance № 3 (SG 90 & 91/2004) Ordinance № 16-116 (SG 26/2008) TS
		At new and/or operational sites / facilities	Circuit breakers - Trigger current, - Impedance voltage - triggering time - resistance of protective earthing	ПП ОК 10-7	Ordinance № 3 (SG 90 & 91/2004) Ordinance № 16-116 (SG 26/2008) TS
		At new and/or operational sites / facilities	Insulation resistance	ПП ОК 10-9 БДС 1986 - p.3.3 a), b), d), e)	Ordinance № 3 (SG 90 & 91/2004) Ordinance № 16-116 (SG 26/2008) TS

* The introduction of a new version of standards/documents or standards/documents, which replace them, is allowed. An actual list of the standards/documents with their dated versions are given by the conformity assessment body.

Ordinance № 6 - on the minimum requirements for ensuring the health and safety of workers in case of risks related to noise exposure (SG № 70/2005);

Ordinance № 6 - on environmental noise indicators taking into account the degree of discomfort during different parts of the day, the threshold values of environmental noise indicators in the premises of residential and public buildings, zones and territories intended for residential construction, recreational zones and territories and zones with mixed purpose, methods for estimating the values of noise indicators and the harmful effects of noise on public health (SG 58/2006 amendment SG 100/2021);

Ordinance № 9 - on the health and hygiene requirements for the use of personal computers in the education and extracurricular activities of students (SG 46/1994);

Ordinance № 24 - on cleaning and sanitary requirements for disco clubs (SG 95/2003);

Ordinance № 2 - on the health requirements for computer and Internet rooms for public use (SG 15/2007);

Ordinance № 26 - on the structure and operation of nurseries and children's kitchens and health requirements for them (SG 103/2008);
Ordinance № 3 - on the health requirements for kindergartens (SG № 15/2007);
Ordinance № RD-07-3 on the minimum requirements for the microclimate of workplaces (SG 63/2014);
Ordinance № 15 - on technical rules and regulations for design, construction and operation of sites and facilities for production, transmission and distribution of heat (SG 68/2005);
Ordinance № 3 - on the design of electrical installations and power lines (SG 90 and 91/2004);
Ordinance № 16-116 on technical maintenance of power equipment (SG 26/2008);
Ordinance № 4 on lightning protection of buildings, outdoor facilities and open-air spaces (SG 6/2011);
Ordinance № 49 - on artificial lighting of buildings (SG № 7/1976);
Ordinance № RD-02-20-3 for design, construction, maintenance of public maintenance buildings in the field of education and science, healthcare, culture and arts (SG 5/2016)
Ordinance № 6 - on ensuring a normal acoustic environment in residential and public buildings and places (SG № 16/1977);
TS - Technical specification.

I HEREBY ORDER

To issue a Certificate of Accreditation with reg. number 98 OKC of 27.12.2024, valid until 27.12.2028, and enclose this order as an integral part thereof.

The Certificate of Accreditation with enclosure should be obtained from Manager of STM-Vita LTD, Razgrad, the Head of the Type C inspection body at STM-Vita LTD, Razgrad or another authorized person in the building of EA BAS.

Upon reception of the issued Certificate of Accreditation with enclosures, the accredited body shall return to EA BAS the original Certificate of Accreditation with reg. number 98 OKC of 29.12.2020 and the enclosure - Order № A 803/29.12.2020.

This order must be notified to the legal entity/sole trader within 3 (three) days following its issuing.

Eng. Irena Borislavova

*Executive Director
of Executive Agency Bulgarian Accreditation Service*

