



ORDER

№ A 25

Sofia, 29.01.2025

On the grounds of art. 10, para. 1, item 4 and art. 28, para. 1 of the Law on the National Accreditation of Conformity Assessment Bodies and item 4.3.7 of the Accreditation Procedure BAS QR 2 in connection with an open procedure with reg. № 339/109 OKC/ПА/16.07.2024, assessment report № 339/109 OKC/ПА/4/B/09.09.2024, section G-2 reg. № 339/109 OKC/ПА/B/06.12.2024 and statement of the Accreditation Commission № 339/109 OKC/ПА/2/B/08.01.2025, I hereby

RE-ACCREDIT

Inspection Body of type C at LOMBARD 2009 LTD, city of Varna

Management and office address:

9000 City of Varna, 24, Chinar Street, apt. 16

To perform inspection according to the following scope:

Scope type: *flexible**

№	Field of inspection	Type of inspection	Parameter of Inspection/ Characteristic	Test and Measurement Methods Used During Inspection, Inspection Procedure	Regulations, Standards, Specifications, Schemes
1	2	3	4	5	6
1.	Artificial lighting in working and living environment	New and/or in operation sites/facilities	Illuminance	Methodological instructions for measurement and assessment of artificial lighting in buildings 40-85, Publishing House Standardization 1985 ПК 7-4	Ordinance № 49 (SG. Issue 7/1976) Ordinance № 24 (SG, issue 95/2003) Ordinance № 9 (SG, issue 46/1994) Ordinance № 3 (SG, issue 15/2007) Ordinance № 2 (SG, issue 15/2007) БДC EN 12464-1 TC
2.	Microclimate in working and living environment	New and/or in operation sites/facilities	- Temperature of the air; - Relative humidity of the air; - Speed of movement of the air.	БДC 16686 Ordinance № ПД 07-3 (SG, issue 63/2014) ПК 7-3	Ordinance № 9 (SG. issue 46/1994) Ordinance № 3 (SG. issue 15/2007) Ordinance № 24 (SG. issue 95/2003) Ordinance № 2 (SG, issue 15/2007) БДC 14776 Ordinance № ПД 07-3 (SG, issue

					63/2014) TC
3.	Noise in working environment	New and/or in operation sites/facilities	- Daily level of noise exposition; -Average weekly level of noise exposition; -Peak level of sound pressure.	БДС EN ISO 9612 (БДС ISO 1999) ПК 7-7	Ordinance 6 (SG. issue 70/2005) TC
4.	Noise in rooms of residential and public buildings	New and/or in operation sites/facilities	- Level of noise; - Equivalent noise of level.	БДС 15471 ПК 7-7	Ordinance № 6 (SG. issue 58/2006, Annex № 2, Table № 1) Ordinance № 9 (SG, issue 46/1994) Ordinance № 24 (SG, issue 95/2003) Ordinance № 2 (SG, issue 15/2007) TC
5.	Electrical installation and facilities up to 1000 V	New and/or in operation sites/facilities	Resistance of isolation	БДС 1986 - 3.3 a), b), e), f) ПК 7-9	Ordinance № 3 (SG. issue 90 and 91/2004) Ordinance № 16-116 (SG, issue 26/2008) TC
6.	Electrical installation and facilities up to 1000 V	New and/or in operation sites/facilities	Impedance of the contour "phase – protective conductor"	ПК 7-2 Version 01/01 31.05.2013	Ordinance № 3 (SG. issue 90 and 91/2004) Ordinance № 16-116 (SG, issue 26/2008) TC
7.	Electrical installation and facilities up to 1000 V	New and/or in operation sites/facilities	Resistance of protective earthing systems	ПК 7-6 Version 01/01 31.05.2013	Ordinance № 3 (SG. issue 90 and 91/2004) Ordinance № 16-116 (SG. issue 26/2008) TC
8.	Electrical installation and facilities up to 1000 V	New and/or in operation sites/facilities	Resistance of lightning protection earthing systems	ПК 7-8 Version 01/01 31.05.2013	Ordinance № 4 (SG, issue 6/2011) TC
9.	Electrical installation and facilities up to 1000 V	New and/or in operation sites/facilities	Circuit breakers: - Trigger current; - Shutdown time; - Tangential voltage.	ПК 7.1 Version 01/01 31.05.2013	Ordinance № 3 (SG, issue 90 and 91/2004) Ordinance № 16-116 (SG, issue 26/2008) TC
10.	Ventilation installations	New and/or in operation sites/facilities	- Air flow rate; - Air flow.	БДС 12.3.018 ПК 7-5	Ordinance № 15 (SG, issue 68/2005) TC

**The introduction of a new version of standards/documents or standards/documents that replace them is allowed. An up-to-date list of standards/documents with their dated versions is provided by the Conformity Assessment Body.*

Ordinance № 16-116 on technical operation of energy equipment (SG, issue 26/2008)
Ordinance № 3 for the design of electrical installations and power lines (SG, issue 90/2004 and issue 91/2004)

Ordinance № 4 on lightning protection of buildings, outdoor facilities and open spaces (SG, issue 6/2011)
Ordinance № 2 on health and hygiene requirements for computer and internet rooms for public use (SG, issue 15/2007)
Ordinance № 3 on the health requirements for kindergartens (SG, issue 15/2007)
Ordinance № 6 on the minimum requirements for ensuring the health and safety of workers from the risks related to noise exposure (SG, issue 70/2005)
Ordinance № 6 on environmental noise indicators, taking into account the degree of discomfort during the different parts of the day, the limit values of environmental noise indicators, the methods for assessing the values of noise indicators and the harmful effects of noise on public health (SG, issue 58/2006)
Ordinance № 9 on the health and hygiene requirements for the use of personal computers in the teaching and extracurricular activities of students (SG, issue 46/1994)
Ordinance № 24 on the sanitary and hygienic requirements for discos (SG, issue 95/2003)
Ordinance № 49 on artificial lighting of buildings (SG, issue 7/1976)
Ordinance № ПД-07-3 on the minimum requirements for the workplace microclimate (SG, issue 63/2014)
Ordinance 15 on the technical rules and regulations for the design, construction and operation of sites and facilities for the production, transmission and distribution of heat (SG, issue 68/2005)
Methodical instructions for measurement and evaluation of artificial lighting in buildings 40-85, Publishing House Standardization 1985
TC Technical Specification of the customer.

I ORDER

The issuance of Certificate of accreditation reg. № 109 OKC from 29.01.2025, valid until 29.01.2029 with this order enclosed as an integral part thereof.

The Certificate of accreditation together with its enclosure shall be received by the LOMBARD 2009 LTD, Varna, the Head of the Conformity assessment body or other authorized person in the office of EA BAS.

Upon receipt of the certificate issued and enclosure, the accredited person is obligate to return to EA BAS the originals of Certificate of Accreditation reg. № 109 OKC/29.01.2021 and the enclosure Order for Accreditation № A 44/29.01.2021 of EA BAS.

This Order shall be notified to the legal entity/the single owner within 3 (three) days as from its issuance.

Dipl. Eng. IRENA BORISLAVOVA
Executive Director
EA BAS

