REPUBLIC OF BULGARIA
Executive agency
Bulgarian accreditation service

Signatory to the EA Multilatetal Agreement in this field

ORDER

№ А 334
Sofia, 31.10.2025

On the basis of Art.10, para.1, item 4 of the Law for National Accreditation of Bodies for Assessment of Conformity and item 6 from the Accreditation Procedure BAS QR 2, in connection with an open procedure reg. No 108/297 ОКС/ПА/13.03.2025, Report for evaluation on site Reg. No 108/297ОКС/ПА/4/В/26.06.2025, and opinion of the Accreditation Commission Reg. No 108/297ОКС/ПА/9/В/10.10.2025

RE-ACCREDIT

INSPECTION BODY OF TYPE C

at STM – PAZARDZHIK EOOD, PAZARDZHIK

Address of management:
4400 Pazardzhik, 4 Kozloduy Str., floor 1, flat 1

Address of the office:
4400 Pazardzhik, 12 Kocho Chestimenski Str.

To perform inspection of:

*Type of scope: flexible**

No	Area of control	Type of control	Controlled parameter / characteristic	Testing / measurement methods used by the control	Normative acts, standards, specifications, schemes
1.	Microclimate in the working environment and living environment	Control of new facilities and sites and/or facilities and sites in operation	Air temperature Relative humidity Air velocity	БДС 16686 Ordinance No РД-07-3(SG, issue 63/2014) РПК 7.1.1-4	БДС 14776 Ordinance No РД-07-3, (SG, issue 63/2014) ТС
2.	Noise in residential and public buildings	Control of new facilities and sites and/or facilities and sites in operation	Noise level, dBA, Equivalent noise level, dBA	БДС 15471 РПК 7.1.1-7	Ordinance No 6, (SG, issue 58/2006) – Annex No 2, table 1 ТС
3.	Environmental noise in various territories and spatial planning zones within and outside urbanized areas	Control of new facilities and sites and/or facilities and sites in operation	Equivalent noise level, dBA	БДС 15471 РПК 7.1.1-8	Ordinance No 6, (SG, issue 58/2006) Annex No 2, table 2 ТС
4.	Noise in the working environment	Control of new facilities and sites	Equivalent noise level, dBA	БДС EN ISO 9612 (БДС ISO 1999)	Ordinance No 6, (SG, issue 70/2005) ТС

52 A "Dr. G. M. Dimitrov" Blvd. 1797 Sofia Bulgaria
phone: +359 2 9766 401; fax: +359 2 873 53 02
e-mail: office@nab-bas.bg; web: www.nab-bas.bg

		and/or facilities and sites in operation	Daily noise exposure level, dBA Average weekly noise exposure level, dBA Peak sound pressure level, dBC	РПК 7.1.1-6	
5.	Artificial lighting in the work environment and living environment	Control of new facilities and sites and/or facilities and sites in operation	Illumination	Methodical instructions for measurement and evaluation of artificial lighting in buildings 40-85, Standartizatsia Publishing House, 1985 РПК 7.1.1-5	Ordinance No 49, (SG, issue 7/1976) БДС EN 12464-1; ТС
6.	Electrical appliances and equipment up to 1000V	Control of new facilities and sites and/or facilities and sites in operation	Circuit breakers: - Trigger current - Touch voltage	РПК 7.1.1-3	Ordinance No 16-116, (SG, issue 26/2008) Ordinance No 3, (SG, issue 90 and issue 91/2004) ТС
7.	Electrical appliances and equipment up to 1000V	Control of new facilities and sites and/or facilities and sites in operation	Impedance Zs of the "phase-protective conductor" circuit	РПК 7.1.1-1	Ordinance No 16-116, (SG, issue 26/2008) Ordinance No 3, (SG, issue 90 and issue 91/2004) ТС
8.	Electrical appliances and equipment up to 1000V	Control of new facilities and sites and/or facilities and sites in operation	Resistance of protective earthing systems	РПК 7.1.1-2	Ordinance No 16-116, (SG, issue 26/2008) Ordinance No 3, (SG, issue 90 and issue 91/2004) ТС
			Resistance of lightning protection earthing systems	РПК 7.1.1-2	Ordinance No 4, (SG, issue 6/2011)
			Resistance of the neutral conductor to earth	РПК 7.1.1-2	Ordinance No 16-116, (SG, issue 26/2008) Ordinance No 3, (SG, issue 90 and issue 91/2004) ТС

* The introduction of a new version of standards/documents replacing them is permitted. Up-to-date list of standards/documents with their dated versions is provided by the Conformity Assessment Body

1. Ordinance № 16-116 (SG, issue 26/2008) on the technical operation of the energy equipment;
2. Ordinance № 3 (SG, issue 90 and 91/2004) on the design of the electrical installations and power lines
3. Ordinance № 4 (SG, issue 6/2011) on the lightning protection of the buildings, external facilities and open spaces;
4. Ordinance № РД-07-3/18.07.2014 (SG, issue 63/2014) on the minimum requirements for the microclimate on the workplaces;
5. Ordinance №. 6 (SG, issue 58/2006) on the environmental noise indicators reflecting the degree of discomfort during different parts of the day, the limit values of environmental noise indicators in the premises of residential and public buildings, in zones and territories designated for residential development, recreational zones and areas, and mixed-use zones, as well as the methods for assessing the values of noise indicators and the adverse health effects of noise on the population
6. Ordinance № 6, SG, issue 70/2005 on the minimum requirements for ensuring the health and safety of workers in case of risks related to the noise exposure;
7. Methodical instructions for measurement and evaluation of artificial lighting in the buildings 40-85, Standartizatsia Publishing House, 1985.
8. Ordinance № 49, SG, issue 7/1976 for the artificial lighting of the buildings;
9. TC

I HEREBY ORDER

To issue a Certificate for accreditation with registration No 297 OKC from 31.10.2025, valid until 31.10.2029 and as an annex this order, an integral part of it.

The certificate of accreditation together with the annex should be received by the Manager/Representative of STM-PAZARDZHIK EOOD, town of Pazardzhik, the Head of OOC or other authorized person in the building of EA BAS.

Upon receipt of the issued certificate and annex, the accredited person is obliged to return to the Executive Agency of the Bulgarian Accreditation Service the originals of the Accreditation Certificate Reg. No 297 OKC from 01.11.2021 and the annex – order No A 677 from 01.11.2021 of the EA of BAS.

This Order should be made known to the STM-PAZARDZHIK EOOD, town of Pazardzhik within 3 (three) days of its issue.

eng. Mariya Ilieva - Yordanova
Executive Director of EA BAS