



REPUBLIC OF BULGARIA
Executive agency
Bulgarian accreditation service



Signatory to the EA Multilateral Agreement in this field

BAS QF 2.11

ORDER

Nº A 376

Sofia, 02.12.2025

Pursuant to Art. 10, para. 1, item 2a of the Law on the National Accreditation of Conformity Assessment Bodies and according to item 5.3.1 in connection with item 4.3.8 c) of the BAS QR 2 Accreditation Procedure, in connection with report 2.9.5.5 with reg.№ 16/121 OKA/4/B/15.08.2025, assessment report with № 16/121 OKA/9/B/09.10.2025, Annex reg. № 16/121 OKA/14/B/28.10.2025, and order of the BSA EA № A 375/02.12.2025, I hereby

AMEND

Gorski Kut-44-Stoynev & Co, Mala Tsarkva village

INSPECTION BODY of type A

Management and office address: 2021 Mala Tsarka village, Samokov

To perform inspection:

Type of scope: fixed					
Nº	Field of inspection	Type of inspection	Controlled Parameter/Characteristic	Test/Measurement Method Used	Regulatory acts, standards, specifications, schemes
1.	Electrical installations and equipment up to and above 1000 V.	Installed on new and/or used sites/facilities	Insulation resistance	Procedure № 1, version № 9, rev. 7, 08.08.2025	Ordinance №3 SG № 90, 91/2004; amended and supplemented SG 42/09.06.2015); Ordinance №16-116, SG №26/2008, amended and supplemented SG № 42/09.06.2015 TC
2.	Electrical installations and equipment up to and above 1000 V	Installed on new and/or used sites/facilities	Resistance of protective grounding (earthing) installations	Procedure № 2, version № 9, rev. 7, 08.08.2025	Ordinance №3 SG № 90, 91/2004, amended and supplemented SG № 42/09.06.2015 Ordinance №16-116, SG №26/2008; № 91/2004; amended and supplemented SG 42/09.06.2015); TC
3.	Electrical	Installed on new	Resistance of	Procedure № 3,	Ordinance № 4

	installations and equipment up to and above 1000 V.	and/or used sites/facilities	lightning protection grounding (earthing) installations	version № 9, rev. 7, 08.08.2025	(SG, № 6/2011); TC
4.	Electrical installations and equipment up to and above 1000 V	Installed on new and/or used sites/facilities	Impedance Zs of the "phase - protective conductor" circuit	Procedure № 4, version № 9, rev. 7, 08.08.2025	Ordinance №3 SG № 90, 91/2004, amended and supplemented SG № 42/09.06.2015 Ordinance № 16-116, SG № 26/2008; TC
5.	Artificial lighting in work and domestic environments	Installed on new and/or used sites/facilities	Illuminance	Methodical guidelines for measuring artificial lighting in buildings", Methodology, item 4 of NCHMEN (National Center for Hygiene, Medical Ecology and Nutrition); Procedure № 5, version № 9, rev. 7, 08.08.2025	БДC EN 12464-1:2021; Ordinance № 2 (SG № 15/2007) Ordinance № 9 (SG № 46/1994); Ordinance № 24 (SG № 95/2003, as amended and supplemented, SG № 100/14.11.2023); Ordinance № 49 (SG № 7/1976, as amended and supplemented, SG № 64/1976); TC
6.	Microclimate in work and domestic environments	New and/or in-service facilities and installations	Air temperature; Air velocity; Relative air humidity;	БДC 16686:1987; Ordinance № ПД-07-03; SG № 63/2014. Procedure № 6, version № 9, rev. 7, 08.08.2025.	Ordinance № ПД-07-03 SG № 63/2014; Ordinance № 9 SG № 46/1994; Ordinance № 2 SG № 15/2007 Ordinance № 24 SG № 95/2003, as amended and supplemented, SG № 100/14.11.2023; БДC 14776:1987; TC

Ordinance № 3 (SG № 90/2004 and № 91/2004) on the structure of electrical systems and power transmission lines;
Ordinance № 16-116 (SG № 26/2008) on the technical use of power equipment;
Ordinance № 4 (SG № 6/2011) on the lightning protection of buildings, outdoor facilities and open spaces;
Ordinance № 2 (SG № 15/2007) on computer and internet rooms for public use;
Ordinance № 9 (SG № 46/1994) on health and hygiene requirements for the use of personal computers in education and extracurricular student activities
Ordinance № 24 (SG № 95/2003) on sanitary-hygienic requirements for discos;
Ordinance № 49 (SG № 7/1976) on artificial lighting in buildings;
Ordinance № ПД-07-03 (SG № 63/2014) on minimum requirements for workplace microclimate;
TC – technical specification.

I ORDER

To issue the certificate of accreditation reg. № 121 OKA/02.12.2025, validity until 27.11.2028, and this order as an integral part of it.

The certificate of accreditation with the enclosure to be received by the Manager of the legal entity, the head of the CAB, or other authorized person in the office of EA BAS.

Upon receipt of the certificate and the enclosure, the accredited person is obliged to return to EA BAS the originals of accreditation certificate Reg. No 121 OKA/27.11.2024 and its enclosure order № A 438/27.11.2024.

This order shall be notified to Gorski Kut 44-Stoynev & Co, Mala Tsarkva village within 3 (three) days from its issuance.

Executive Director of EA BAS

eng. Mariya Ilieva-Yordanova

