



ORDER

№ A 314

Sofia, 13.05.2022

Pursuant to Art. 10, para. 1, item 2 and Art. 20, para. 6 of the Law on National Accreditation of Conformity Assessment Bodies and item 4 of the BAS QR 2 Accreditation Procedure, in connection with an open procedure for initial accreditation reg. № 491-ЛИ/25.02.2021, assessment reports reg. № 491 ЛИ /B/24.01.2022, reg. № 491 ЛИ/12/B/31.03.2022 and statement of the Accreditation Commission reg. № 491 ЛИ/13/B/04.05.2022, I hereby

ACCREDIT

**Test center TESTEN Ltd.
Testing Laboratory**

Management address: 9000 Varna, 128, 8-mi Primorski Polk Blvd, office 304
Laboratory address: 9300 Dobrich, 68, Kaliakra Str.

To perform testing of:

Type of scope: <i>Fixed</i>			
№	Tested products	Type of test / characteristic	Testing methods (standard / validated method)
1	2	3	4
1.	Electrical panels (1). Communication cabinets (2). Server cabinets (3), part of the composition of automated technological process control systems in the nuclear power plant.	Testing of stability and resistance when the specimen is operated by vibration (with acceleration from 0.1 g to 10 g in a specified direction - X, Y, Z axes and frequency from 1 Hz to 35 Hz).	ПИ 7.2.1.1/10.02.2022

Reference:

ПИ 7.2.1.1/10.02.2022 Vibration testing methodology for resistance to anthropogenic effects
– air shock wave simulation and aircraft drop simulation.

I ORDER

To issue the Certificate of accreditation reg. № 292 ЛИ/13.05.2022, valid until 13.05.2026, and this order as an integral part of it.

The Certificate of accreditation with the enclosure to be received by the Manager / representative of the Test center TESTEN Ltd, the head of the Testing Laboratory at Test center TESTEN Ltd, or other authorized person in the office of EA BAS.

This order shall be notified to the Test center TESTEN Ltd, within 3 (three) days from its issuance.

Eng. Irena Borislavova

Executive Director of EA BAS

