



Republic of Bulgaria  
Executive Agency  
Bulgarian Accreditation Service



Signatory to the EA Multilateral Agreement in this field

**ORDER**

**№ A 424**  
**Sofia, 02.10.2023**

Pursuant to Art. 10, para 1, item 4 and Art. 28, para 1 of the National Accreditation of Conformity Assessment Bodies Act, and in accordance with item. 4.3.7 of the Accreditation Procedure BAS QR 2, in connection with an open procedure reg. No 277/26 OKC/ПА/20.02.2023, Assessment Report reg. No 277/26 OKC/ ПА/ 5/B/26.06.2023, Section G-2 reg. No 277/26 OKC/ 2/ B/30.06.2023 and statement of the Accreditation Commission No 277/26 OKC/ 9/ B/15.09.2023, I hereby.

**RE- ACCREDIT**

**Inspection Body Type C**  
**„ELSTAR CONSULT” LTD Varna**

**Registered office address:**  
9000, Varna, 62 „Br. Miladinovi” St., fl.3, apt.6

**Office address:**  
9000, Varna, 12 „Knyaz. Batenberg” St, office 1

**To perform inspection, according to the following scope:**

Type of scope: fixed

No	Field of Inspection	Type of Inspection	Parameter of Inspection / Characteristic	Test and Measurement Methods Used During Inspection	Regulations, Standards, Specifications, Schemes
1	2	3	4	5	6
1.	Electrical systems and facilities for voltage up to 1000 V	On new and / or operational sites and equipment	Impedance of the loop „phase-protected” wire	PK 01-01; Ed.04/2014	Ordinance No 3, SG, issue 90, 91/2004; Ordinance No 16-116, SG, issue 26/2008; TC.
2.	Electrical systems and facilities for voltage up to 1000 V	On new and / or operational sites and equipment	Resistance of protective earthing system	PK 02-01, Ed.04/2014	Ordinance No 3, SG, issue 90, 91/2004; Ordinance No 16-116, SG, issue 26/2008; TC.
3.	Electrical systems and facilities for voltage up to 1000 V	On new and / or operational sites and equipment	- Resistance on lightning protection earthing arrangements	PK 03-01, Ed.04/2014	Ordinance No 4, SG, issue 6/2011; TC.

52 A „Dr. G. M. Dimitrov” Blvd. 1797 Sofia Bulgaria  
phone: +359 9766 401; fax: (+3592) 9766 415  
e-mail: office@nab-bas.bg

4.	Electrical systems and facilities for voltage up to 1000 V	On new and / or operational sites and equipment	Circuit breakers -Resistance of protective earthing -Tripping current	PK 04-01, Ed.05/2018	Ordinance No 3, SG, issue 90, 91/2004; Ordinance No 16-116, SG, issue 26/2008; TC.
----	--	---	---	-------------------------	--

Ordinance No 4 on the lightning protection of buildings, outdoor facilities and open spaces (SG, issue 6/2011);  
Ordinance No 3 on the design of electrical installations and power lines, SG, issue 90 and 91/2004, amend. SG No. 42/2015 );  
Ordinance No 16-116 on the technical operation of electrical equipment (SG, issue 26/2008, amend. SG No. 42/2015 );  
TC – Technical specification.

### I HEREBY ORDER

The issuance of Certificate for accreditation with registration No. 26 OKC dated 02.10.2023 valid until 02.10.2027 and this order enclosed as an integral part thereof.

The certificate of accreditation with the enclosure should be obtained from Manager of **"ELSTAR CONSULT" LTD, Varna**, the Head of **Inspection Body of Type C** at **"ELSTAR CONSULT" LTD, Varna** or other authorized person in the building of EA BAS

Upon receipt of the certificate issued and enclosure, the accredited CAB is obliged to return to EA BAS the originals of Certificate of Accreditation Reg. No. 26 OKC / 10.02.2021 , valid until 30.09.2023 and the enclosure Order for Accreditation EA BAS Order No. A 53/ 10.02.2021.

This Order shall be notified to legal entity / sole within 3 (three) days from its issuance.

Eng. **IRENA BORISLAMOVA**

Executive Director of EA BAS

