Republic of Bulgaria
Executive Agency
Bulgarian Accreditation Service

Signatory to the EA Multilateral Agreement in this fied

BAS QF 2.11

ORDER

No. A 82

Sofia, 19.02.2021

Pursuant of Art. 10, para 1, item 2a and Article 32, item 1 of the Law on National Accreditation of Conformity Assessment bodies, according to the item 5.3 in connection to item 4.3.8 f) of the Accreditation Procedure BAS QR 2, with regard to Assessment report, ref. № 431/153 ОКС/14/В/12.10.2020, application with entry № 431/153 ОКС /15/В/Р/12.10.2020 and order № А 81/19.02.2021, I hereby

I AMEND EA BAS ORDER № А 9/07.01.2020
INSPECTION BODY OF TYPE C „OK CONTROL", Botevgrad
„O KEY PLUS" EOOD, Vratsa

Management address: 3000 Vratsa, 7 Krastyo Balgariyata St., Apt.3

Office address: 2140 Botevgrad 92 Al. Stamboliyski St.

To perform inspection of:

Type of scope: flexible*

No	Field of Inspection	Type of Inspection	Parameter of Inspection/Characteristic	Test and Measurement Methods Used During Inspection, Inspection Procedure	Regulations, Standards, Specifications, Schemes
1	2	3	4	5	6
1.	Microclimate in work and living media	New and / or sites / equipment in operation	-temperature of air -relative humidity of air -velocity of movement of air	БДС 16686 ПК 7.1-01 Ordinance Nr.RD-07-3 (State gazette No. 63/2014)	Ordinance No.RD-07-3 (St.G. No.63/2014) Ordinance No.2 (St.G. No.15/2007) Ordinance No.3 (St.G. No.15/2007) Ordinance No.9 (St.G. No.46/1994) Ordinance No.24 (St.G. No.95/2003) Ordinance No.26 (St.G. No.103/2008) БДС 14776 TS
2.	Artificial lighting in work and living media	New and / or sites / equipment in operation	illumination	Methodological instructions for measuring and assessment of artificial in buildings 40-85, Issue standardization year 1985 ПК 7.1-12	БДС EN12464-1 БДС EN12464-2 Ordinance No.49 (St.G. No.7/1976) Ordinance No.9 (St.G. No.46/1994) Ordinance No.24 (St.G. No.95/2003) Ordinance No.2 (St.G. No.15/2007)

52 A "Dr. G. M. Dimitrov" Blvd. 1797 Sofia Bulgaria
phone: +359 9766 401; fax: (+3592) 9766 415
e-mail: office@nab-bas.bg

					Ordinance No.3 (St.G. No.15/2007) TS
3	Noise in work media	New and / or sites / equipment in operation	-Daily level of exposition of noise; -Average weekly level of exposition of noise; -Extreme level of sound pressure -level of noise; -equivalent level of noise;	БДС EN ISO 9612 (БДС ISO 1999) РК 7.1-12 БДС 15471 ПК 7.1 - 12	Ordinance No.6 (St.G. No.70/2005)
4	Noise in premises of residence and public buildings	New and / or sites / equipment in operation	-level of noise; -equivalent level of noise;	БДС 15471 ПК 7.1 - 03	Ordinance No.6 (St.G. No.16/1977) Ordinance No.6 Supplement No.2 Table No.1 (St.G.58/2006 Ordinance No.2 (St.G. No.15/2007) Ordinance No.9 (St.G. No.46/1994) Ordinance No.24 (St.G. No.95/2003) Ordinance No.26 (St.G. No.103/2008) TS
5	Ambient noise	New and / or sites / equipment in operation	Equivalent level of noise;	БДС 15471 ПК 7.1 - 03	Ordinance No.6 Supplement No.2 Table No.2 (St.G.58/2006
6	Electrical devices and equipment up to and over 1000 V	New and / or sites / equipment in operation	Resistance of protective earth grounding devices	ПК 7.1 - 04	Ordinance No.3 (St.G. No.90 & 91/2004) Ordinance No.16 - 116 (St.G. No.26 /2008) TS
7	Electrical devices and equipment up to and over 1000 V	New and / or sites / equipment in operation	Resistance of protective lightning protection earth grounding devices	ПК 7.1 - 05	Ordinance No.4 (St.G. No.6/2011) TS
8	Electrical devices and equipment up to 1000 V	New and / or sites / equipment in operation	Impedance of the "phase-protective conductor" loop	ПК 7.1 - 06	Ordinance No.3 (St.G. No.90 & 91/2004) Ordinance No.16 - 116 (St.G. No.26 /2008) TS
9	Electrical devices and equipment up to 1000 V	New and / or sites / equipment in operation	Protective circuit breakers: -inrush current; -time of switching off; -touch voltage;	ПК 7.1 - 07	Ordinance No.3 (St.G. No.90 & 91/2004) Ordinance No.16-116 (St.G. No.26 /2008) TS
10	Electrical devices and equipment up to and over	New and / or sites / equipment in	Resistance of insulation up to 1000V.	БДС 1986, Р.3.3 a), b), c), d) ПК 7.1 – 08	Ordinance No.3 (St.G.90 & 91/2004) Ordinance No.16-

	1000 V; Cables and cable lines up to 35 kV	operation	Resistance of insulation above 1000V via control with increased voltage: - with direct voltage up to 10kV -with industrial frequency up to 35kV	ПК7.1. – 09;	116 (St.G.26/2008_ NIEMS – 1995 TS
11	Electrical protection means				
11.1	Dielectric gloves, boots and galoshes; Insulation elastomer covers and caps; insulation ropes of synthetic material	Products in process of operation	- electrical insulation strength by industrial frequency increased voltage control -leakage current	Ordinance No.22 (St.G. No.45/2006) ПК7.1-10	Ordinance No.22 (St.G. No.45/2006) ПК7.1-10
11.2	insulating bars, measuring rod heads, insulating bars for portable earthing devices, insulating pliers, insulating hard dielectric covers and caps, dielectric mats and runners, insulating stands, insulating ladders		- electrical insulation strength by industrial frequency increased voltage control		
11.3	voltage pointers, phase matching check pointers	Products in process of operation	- electrical insulation strength by industrial frequency increased voltage control; - voltage indication threshold /voltage threshold/	Ordinance No.22 (St.G. No.45/2006) ПК7.1-10, version 1 of 13.7.2015	Ordinance No.22 (St.G. No.45/2006)
12	Ventilation installations	New and / or sites / equipment in operation	-velocity of movement of air current; -debit of air	БДС 12.3.018 ПК 7.1.11	Ordinance No.15 (St.G. No.68/2005) TS

***Introduction of new version of standards/documents or standards/documents that are replacing them in a permitted way. Actual list of standards / documents with their dated versions are provided by CAB.**

Ordinance No. RD -07-3 (St.G.No. 63/2014) for minimal requirements of microclimate of work places;
Ordinance No.2 (St.G.No. 15/2007) for requirements in computer and internet rooms with public usage;
Ordinance No.3 (St.G.No. 15/2007) for sanitary requirements in kindergartens:
Ordinance No.9 (St.G.No. 46/1994) for sanitary and hygiene requirements for personal computers in training and extra-schooling activities of students / pupils;

Ordinance No. 24 for sanitary-hygiene requirements for discotheques (St.G. No.95/2003)
Ordinance No. 26 for the organization and operation of nurseries and children kitchens and sanitary requirements to them (St.G. 103 / 2008);
Ordinance No. 49 for artificial lighting of buildings (St.G. 7 / 1976);
Ordinance No. 6 (St. G. No. 70 / 2005) form minimal requirements for provision of health and safety of working in risks that are connected with exposition to noise
Ordinance No.6 (St.G. No.58 / 2006) for pointers to noise in ambient media, showing the degree of discomofort in various parts of the night and day, border values of the pointers to noise in ambient media, methodology of assessment of the values of pointers to noise and harmful effects by noise to health of population.
Ordinance No.7 (St.G. No.88/1999) minimal requrements for sanitary and safe conditions for work places and with use of work equipment;
Ordinance No.6 (St.G.16 / 1977) for provision of normal acustic conditions in residence and public buildings and places;
Ordinance No.3 (St.G.45 / 2006) for organization of electrical devices and electrical conductor lines;
Ordinance No.16-116 (St.G. 26 / 2008) for technical operation of energy supply;
Ordinance No. 4 (St.G. No. 6 / 18.1.20??) for lightning protection of buildings, equipment in the open and open spaces;
Ordinance No.22 (St.G. No. 45 / 18.1.2006) for testing protection means in operation;
Ordinance No. 15 (St.G. No. 68/2005) for technical rules and norm acts relating to design, construction and operation of sites and equipment for production, transfer and distribution of heat energy;
Methodology instructions for measuring and assessment of artificial lighting in buildings 40-85, issue Standardization, 1985.


I ORDER

To issue the Certificate of Accreditation reg. № 153 OKC of 19.02.2021, valid until 07.01.2024 and this order enclosed as an integral part thereof.

The Certificate of Accreditation together with the enclosure should be received by the Manager of OK Control with O-Key PLUS EOOD, the manager of Body of Control of the type "OK Control" or other authorized person.

Upon receipt of the certificate for accreditation issued and enclosure, Accredited person is obliged return to IA BSA the originals of the certificate for Accreditation reg. № 153/07.01.2020 and the enclosure order of EA BAS No. A 9/07.01.2020.

This order shall be notified to legal entity/sole trader within 3 (three) days from its issuance.



Eng. Irena Borislavova
Executive Director of EA BAS