



ORDER

№ A 39
Sofia, 23.01.2024

On the grounds of art. 10, para. 1, item 4 and art. 28, para. 1 of the Law on the National Accreditation of Conformity Assessment Bodies and item 4.3.7 of the Accreditation Procedure BAS QR 2 in connection with an open procedure with reg. № 427/30 OKC/ПА/07.06.2023, Assessment report ref. № 427/30 OKC/ПА/6/B/04.09.2023, statement of the Accreditation Commission ref. № 427/30 OKC/ПА/B/12.01.2024, I hereby

RE-ACCREDIT

Inspection Body of type C
at ANTIVA CONSULT LTD

Management Address: 5250 Svishtov, 52 Third of March str.
Office address: 5250 Svishtov, 18 Petar Angelov str., p. o. box 30

To perform inspection of:

Type of the scope: flexible*					
№	Field of Inspection	Type of Inspection	Parameter of Inspection / Characteristic	Test and Measurement Methods Used During Inspection, Inspection Procedure	Regulations, Standards, Specifications, Schemes
1	2	3	4	5	6
1.	Ventilation installations	New and/or in use/ operation sites/ facilities	Air flow rate, Air flow speed	БДC 12.3.018; PC7.I-2	Order № 15 (State Gazette Issue 68/2005); Technical specification
2.	Working and household environment microclimate	New and/or in use/ operation sites/ facilities	Air temperature; Air flow speed; Relative humidity	Ordinance № ПД-07-3 (SG № 63/2014); БДC 16686; PC 7.1-3	Ordinance ПД-07-3 (SG № 63/2014); Ordinance № 24 (SG 95/2003); Ordinance № 2 (SG № 15/2007); Ordinance № 3/SG № 15/2007; БДC 14776; Technical specification
3.	Noise in working environment	New and/or in use/ operation sites/ facilities	Daily level of exposure to noise; Average level of exposure to noise per week; Maximum level of sound pressure; Equivalent noise level; Noise level	БДC EN ISO 9612 (БДC ISO 1999); БДC 15471; PC 7.1-4	Ordinance № 6 (SG 70/2005); Ordinance № 9 (SG № 46/1994); Ordinance № 7 (SG № 88/1999); Ordinance № 26 (SG № 103/2008); Technical specification

Type of the scope: flexible*

№	Field of Inspection	Type of Inspection	Parameter of Inspection / Characteristic	Test and Measurement Methods Used During Inspection, Inspection Procedure	Regulations, Standards, Specifications, Schemes
1	2	3	4	5	6
4.	Noise in living and public spaces	New and/or in use/ operation sites/ facilities	Equivalent noise level; Noise level	БДС 15471; PC 7.1-5	Ordinance № 6 (SG, № 58/2006) (Annex 2, Table 1); Ordinance № 9 (SG № 46/1994); Ordinance № 24 (SG № 95/2003); Ordinance № 2 (SG, № 15/2007); Ordinance № 26 (SG 103/2008); Technical specification
5.	Noise of the environment – territories in urban and rural spaces	New and/or in use/ operation sites/ facilities	Equivalent noise level	БДС 15471; PC 7.1-6	Ordinance № 6 (SG 58/2006); (Annex 2, Table 2); Technical specification
6.	Artificial light at the work and household environment	New and/or in use operation sites/ facilities	Lightning conditions	Methodical guidelines 40-85 – artificial lighting measurement methods, Standardisation issue; PC 7.1-7	Ordinance № 49 (SG, № 7/1976); Ordinance № 24 (SG № 95/2003); БДС EN 12464-1; Technical specification
7.	Electrical installations and facilities up to 1000 V	New and/or in use/ operation sites/ facilities	Insulation resistance	БДС 1986 i. 3.3, a), b), d), e); PC 7.1-8	Regulation № 3 (SG № 90 and 91/2004); Ordinance № 16-116, (SG, № 26/2008); Technical specification
8.	Electrical installations and facilities up to 1000 V	New and/or in use/ operation sites/ facilities	Resistance of protective grounding systems	PC 7.1-9	Regulation № 3 (SG № 90 and 91/2004); Ordinance № 16-116 (SG, № 26/2008); Technical specification
9.	Electrical installations and facilities up to 1000 V	New and/or in use/ operation sites/ facilities	Resistance of lightning protection grounding systems	PC 7.1-10	Ordinance № 4 (SG № 6 / 18.01.2011.); Technical specification
10.	Electrical installations and facilities up to 1000 V	New and/or in use/ operation sites/ facilities	Impedance of the "phase-protective conductor"	PC 7.1-11	Ordinance № 3 (SG № 90 and 91/2004); Ordinance № 16-116, (SG, № 26/2008); Technical specification
11.	Electrical installations and facilities up to 1000 V Protection against zero sequence currents (ZS)	New and/or in use/ operation sites/ facilities	Actuating current; Tactile voltage; Resistance of the protective earthing device; Shutdown time	PC 7.1-12	Ordinance № 3 (SG № 90 and 91/2004); Ordinance № 16-116 (SG № 26/2008) Technical specification

* The introduction of a new version of standards/documents or standards/documents replacing them is allowed. An updated list of standards/documents and their dated versions is provided by CAB.

Order № 3 - related to the arrangement of electrical devices and power lines, SG, i. 90 and i. 91/2004;

Order № 16-116 – related to technical operation of energy equipment, SG, i. 26/2008;

Order № 4 – related to lightning protection of buildings, outdoor facilities and open spaces, SG i. 45/2006;
Order № ПД-07-3 – related to the minimum requirements for the microclimate at the work place, SG, I. 63/10.08.2014;
Order № 2 – related to the health requirements for computer and internet rooms for public use, SG, i. 15/2007;
Order № 3 – related to the health requirements for kindergartens, SG, i. 15/2007;
Order № 6 - related to minimum requirements for health insurance and the safety of the employees at risks of noise exposure, SG i. 70/2005;
Order № 6 from 2006 (SG, i. 58/2006) related to the environmental noise indicators, indicating the level of discomfort during different times of the day, the limit values of noise indicators in the environment, in living and public buildings, in areas and territories intended for housing construction, recreational places and territories and mixed use areas, methods for evaluating the values of noise indicators and the harmful effects of noise on the health of the population (amended title – SG, i. 100 from 2021);
Order № 7 – related to the minimal requirements for healthy and safe work conditions at the work place and when using work equipment, SG i. 88/1999;
Order № 9 – related to the health and hygiene requirements for the use of personal computers in the education and extracurricular activities of students, SG. 46/1994;
Order № 15 – related to the technical rules and regulations for the design, construction and operation of the objects and facilities for the production, transmission and distribution of thermal energy, SG i. 68/2005;
Order № 24 – related to the sanitary and hygienic requirements for clubs, SG i. 95/2003;
Order № 26 – related to the organisation and operation of nurseries and children's kitchens and the health requirements for them, SG i. 103/2008;
Order № 49 – related to artificial lighting in buildings (SG, i. 7/1976);
 Methodological guidelines for measurement and evaluation of artificial lighting in buildings 40-85, publishing house "Standartisation" – 1985.


I ORDER

To issue the Certificate of accreditation reg. № 30 OKC/23.01.2024, valid until 23.01.2028 and this order as an integral part of it.

The Certificate of accreditation with the enclosure should be obtained from the manager / representative of the ANTIVA CONSULT LTD, head of the Inspection body of type C, or other authorized person in the office of EA BAS.

Upon receipt of the certificate issued and enclosure, the accredited CAB is obliged to return to EA BAS the originals of the certificate of accreditation with reg. № 30 OKC/25.01.2022 and its enclosure EA BAS order reg. № A 71/25.01.2022.

This order shall be notified to ANTIVA CONSULT LTD within 3(three) days from its issuance.



Eng. Irena Borislayova

Executive Director of EA BAS